

LOCATION

204 Keltie Meadows Dr.

CITY

GASTONIA

BETWEEN

Cape Breton Trl

STREET &

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	50'	10-3-96		
MAIN TO PROP. LINE	3/4"	P	5'			
PROP. LINE TO BLDG.	3/4"	P	45'			

ENTERS:

204

BRANCHED INTO:

TAP SIZE:

1/2

PRESSURE

60

P.S.I.

INCHES W.C.

LOCATION

98' E. of center of

Keltie Meadows Dr

PRESSURE TEST: @

100

psi

For

1/4 Hrs.

By

S. Huffstutler

MAIN-SIZE

2"

C.I.

BARE STEEL

COATED STEEL

PLASTIC

✓

YEAR INSTALLED

1995

DEPTH:

3 Ft.

0 In.

LOCATION

14' N. of center of Cape Breton Trl.

"A" P/S READING

P

TOTAL ANODES 1*

0


17*

0

L.R. #

545377

REMARKS:



Test Station

ENG. DEPT. USE ONLY

Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	