

LOCATION 1102 Kendrick RdCITY GastoniaBETWEEN Robinwood

STREET &

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>P</u>	<u>90'</u>	<u>10-27-99</u>		
MAIN TO PROP LINE	<u>1"</u>	<u>1"</u>	<u>50'</u>			
PROP LINE TO BLDG	<u>1"</u>	<u>1"</u>	<u>40'</u>			

ENTERS: 1102BRANCHED INTO: —TAP SIZE 1/2

PRESSURE

PSI

INCHES W.C.

LOCATION 22' s. of C ofKendrickPRESSURE TEST @ 100 PSI

FOR

12 HRS

BY

ETPMAIN SIZE 6"

C.I.

BARE STEEL

COATED STEEL

PLASTIC

YEAR INSTALLED 1997

DEPTH

6 FT0 IN

LOCATION

"A" P/S READING


1.00

TOTAL ANODES 1#

17#

L.R. #

REMARKS.



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>• R</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>•</u>	