

LOCATION 1122 Kendrick Rd. CITY GASTON, NC

BETWEEN Hoffman Rd. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	3/4"	P	158'	4-16-99		
MAIN TO PROP LINE	3/4"	P	35'			
PROP LINE TO BLDG.	3/4"	P	123'			

ENTERS. 1122 BRANCHED INTO

TAP SIZE 1/2 PRESSURE 60 PSI INCHES WC LOCATION 749' E of center of Hoffman Rd


PRESSURE TEST @ 100 PSI FOR 1 1/4 HRS BY SH

MAIN SIZE 3" C I RARE STEEL COATED STEEL ✓ PLASTIC YEAR INSTALLED

DEPTH 4 FT 0 IN LOCATION 10' S. of center of Kendrick Rd

A P/S READING 1.4 TOTAL ANODES 1# 0 17# 0 L.R. # 282723

REMARKS. Installed EFW.



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	