

LOCATION 1125 Kendrick Rd. Bldg - A CITY GASTONIA  
BETWEEN Barrington Dr STREET & Robinwood Rd. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>200'</u>	<u>2-12-96</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>0'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>200'</u>			

ENTERS: 1125 BRANCHED INTO: 1125 Bldg - A.  
TAP SIZE: 3/8" PRESSURE 600 PSI \_\_\_\_\_ INCHES W.C. LOCATION 1300' w/ of Barrington Dr.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY RL

SERVICE MAIN SIZE 3/4 C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ☒ PLASTIC \_\_\_\_\_ YEAR INSTALLED 1974

DEPTH: 2 FT. 0 IN. LOCATION \_\_\_\_\_

"A" P/S READING 1.3 TOTAL ANODES 1# 0 17# 0 L.R. # 027365

REMARKS: Split Service

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser Plastic</u>	
	P/S Pipeline Lead - White Existing Main	<u>E</u>		