

LOCATION 2054 Kendrick Rd. CITY Gastonia

BETWEEN Eaglebrook DR STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>413'</u>	<u>8-9-00</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>45'</u>			
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>				

ENTERS 2054 BRANCHED INTO

TAP SIZE 1/2 PRESSURE 60 PSI INCHES W C LOCATION 372' W. of center of Eaglebrook DR.


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY S.H.

MAIN-SIZE 4" C I        BARE STEEL        COATED STEEL ✓ PLASTIC        YEAR INSTALLED 1964

DEPTH 3 FT 0 IN LOCATION 11' S. of center of Kendrick Rd.

"A" P/S READING .8 TOTAL ANODES 1# 0 17# 1 LR # 711242

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	