

LOCATION 2301 Kendrick Estates Dr CITY Castonia

BETWEEN Stoney Creek Ct STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>67'</u>	<u>6-4-98</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>40'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>27'</u>			

ENTERS: 2301 BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 144' S. of center of

Kendrick Estates Dr


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. Hunsberty

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1996

DEPTH: 3 FT. 0 IN. LOCATION 18' W. of center of Stoney Creek Ct

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 395734

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY