

LOCATION 2308 Kendrick Est. dr CITY Boston
BETWEEN Stoneycreek st STREET & Leah end STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>116'</u>	<u>9-28-98</u>		
MAIN TO PROP. LINE	<u>11</u>	<u>11</u>	<u>45'</u>			
PROP. LINE TO BLDG.	<u>11</u>	<u>11</u>	<u>71'</u>			

ENTERS: 2308 BRANCHED INTO: —

TAP SIZE: 1/2 PRESSURE _____ PSI _____ INCHES W.C. LOCATION 20' S. of C of Kendrick Est. Dr.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY AP

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1996

DEPTH: 3 FT. 0 IN. LOCATION _____

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	<u>R</u>	<u>P</u>	
	P/S Pipeline Lead - White Existing Main	<u>E</u>		