

LOCATION 2349 KENDRICK ESTATES CITY LASTONIA  
BETWEEN STONE CREEK COURT STREET & DEAD END STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>104'</u>	<u>11-12-96</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>PLASTIC</u>	<u>4'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>100'</u>			

ENTERS: 2349 BRANCHED INTO: 0  
TAP SIZE: 1/2 PRESSURE 60 PSI 0 INCHES W.C. LOCATION 681' N of C of  
STONE CREEK COURT.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY R.R  
MAIN-SIZE 2" C.I.        BARE STEEL        COATED STEEL        PLASTIC ✓ YEAR INSTALLED 1996  
DEPTH: 3' FT. 0 IN. LOCATION 36' E of C of KENDRICK ESTATES.

"A" P/S READING PLASTIC TOTAL ANODES 1# 0 17# 0 L.R. # 00637066

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>PLASTIC</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>Riser</u>

ENG. DEPT. USE ONLY