

LOCATION 3709 Kennedy Rd. CITY Easton
BETWEEN Newcombe Ct. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>8 1/8"</u>	<u>P</u>	<u>107'</u>	<u>9-26-01</u>		
MAIN TO PROP LINE	<u>8 1/8"</u>	<u>P</u>	<u>45'</u>			
PROP LINE TO BLDG	<u>5 1/2"</u>	<u>P</u>	<u>62'</u>			

ENTERS 3709 BRANCHED INTO

TAP SIZE 1/2 PRESSURE 60 PSI _____ INCHES WC LOCATION 143' SW. of center of Newcombe Cr.

PRESSURE TEST @ 100 PSI FOR 14 HRS BY S.H.

MAIN SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED _____

DEPTH 3 FT 0 IN LOCATION 20' SE. of center of Kennedy Rd.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # A0119880

REMARKS

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

