

LOCATION 3716 Kennedy Rd. CITY GASTONIA  
BETWEEN EAST HAMPTON CT. STREET & NEW COMBE LANE STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>		<u>2-7-97</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>PLASTIC</u>	<u>20'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>30'</u>			

ENTERS: 3722 Kennedy Rd. BRANCHED INTO: 3716 Kennedy Rd.  
TAP SIZE: 3/4 STRAIGHT P. Tee PRESSURE: 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 30' E of COF NewCombe Lane


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY RL

~~SERVICE~~ MAIN SIZE 3/4 C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1996

DEPTH: 2 FT. 0 IN. LOCATION 60' S of COF Kennedy Rd.

"A" P/S READING PLASTIC N/A TOTAL ANODES 1# 0 17# 0 L.R. # 042068

REMARKS: SPLIT SERVICE



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>PLASTIC</u>

ENG. DEPT. USE ONLY