

LOCATION 3734 Kennedy Rd. CITY GASTONIA
BETWEEN Laver Ct. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>27'</u>	<u>5-22-98</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>0</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>27'</u>			


ENTERS: 3734 BRANCHED INTO:
TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 71' W. of center of
Kennedy Rd

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. Hufstetler
MAIN SIZE 3/4" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1998

DEPTH: 2 FT. 0 IN. LOCATION 100' N. of center of Kennedy Rd

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 357289

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY