

LOCATION 3782 Kennedy CITY Gastonia

BETWEEN Laver STREET & Dead end STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>45'</u>	<u>7-29-98</u>		
MAIN TO PROP. LINE	<u>1"</u>	<u>1"</u>	<u>5'</u>			
PROP. LINE TO BLDG.	<u>1"</u>	<u>1"</u>	<u>40'</u>			

ENTERS: 3782 BRANCHED INTO: 3788

TAP SIZE: 3/4 PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 627' N of C of Laver


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY BC

MAIN-SIZE 3/4 C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1998

DEPTH: 2 FT. \_\_\_\_\_ IN. LOCATION 104' W. of C of Kennedy

"A" P/S READING plastic TOTAL ANODES 1# 1 17# 1 L.R. # \_\_\_\_\_

REMARKS:

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	<u>SR</u>	<u>P</u>	
	P/S Pipeline Lead - White Existing Main	<u>E</u>		