

LOCATION 3933 Kennedy St CITY Gastonia
BETWEEN Laver Ct STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>5/8"</u>	<u>P</u>	<u>108'</u>	<u>8-16-02</u>		
MAIN TO PROP LINE	<u>5/8"</u>	<u>P</u>	<u>48'</u>			
PROP LINE TO BLDG	<u>5/8"</u>	<u>P</u>	<u>60'</u>			

ENTERS Same BRANCHED INTO

TAP SIZE 1/2" PRESSURE 60 PSI INCHES W/C LOCATION 19' North of

Kennedy St. & 46' west of Laver Ct.

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY B. Ballard

MAIN-SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED

DEPTH 3 FT 6 IN LOCATION 19' North of Kennedy St.

"A" P/S READING Plastic TOTAL ANODES 1# 0 17# 0 LR #

REMARKS New 5/8" plastic serv.

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>p. Riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

