

LOCATION 1244 Kennett Ave CITY Gastonia
BETWEEN Elder Ct STREET & Heritage Commons STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	3/4"	P	95'	11/13/00		
MAIN TO PROP LINE	3/4"	P	15'	"		
PROP LINE TO BLDG	3/4"	P	80'	"		

ENTERS


BRANCHED INTO

TAP SIZE 1/2" PRESSURE 60 PSI INCHES W C LOCATION 311 ft west of center of Elder Ct

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY D. Woody
MAIN SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1998
DEPTH 3' FT 0" IN LOCATION 36' south of center of Kennett Ave.

"A" P/S READING N/A TOTAL ANODES 1# 0 17# 0 LR # 1056992

REMARKS new plastic 3/4" service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	plastic
P/S Pipeline Lead - White Existing Main	E	riser