

LOCATION 1244 Kennett Ave CITY Gastonia
BETWEEN Elder Ct STREET & Heritage Commons STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>95'</u>	<u>11/13/000</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>15'</u>	<u>"</u>		
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>80'</u>	<u>"</u>		

ENTERS _____ BRANCHED INTO _____
TAP SIZE. 1/2" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 311 ft West of center of Elder Ct


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY D. Woody

MAIN-SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1998

DEPTH 3' FT 0" IN LOCATION 36' south of center of Kennett ave.

"A" P/S READING N/A TOTAL ANODES 1# 0 17# 0 LR # 1056992

REMARKS new plastic 3/4" service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>riser</u>