

LOCATION 1249 Kennett Ave. CITY Boston  
BETWEEN Elder St STREET & Cul-de-Sac STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>1/2</u>	<u>P</u>	<u>70'</u>	<u>6-5-01</u>		
MAIN TO PROP LINE	<u>1/2</u>	<u>P</u>	<u>5'</u>			
PROP LINE TO BLDG	<u>1/2</u>	<u>P</u>	<u>65'</u>			

ENTERS 1249 BRANCHED INTO  
TAP SIZE 3/4" PRESSURE 60 PSI INCHES W C LOCATION 300' W. of center of Elder St.

PRESSURE TEST @ 100 PSI FOR 44 HRS BY S. G.  
MAIN-SIZE 2" C I        BARE STEEL        COATED STEEL        PLASTIC        YEAR INSTALLED 2001  
DEPTH 3 FT 0 IN LOCATION 33' S. of center of Kennett Ave.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 LR # AO 434734

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	