


LOCATION 1255 Kennett Ave. CITY Gastonia
 BETWEEN Elder Ct. STREET & Heritage Commons Dr STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>81'</u>	<u>2-12-01</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>5'</u>	<u>"</u>		
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>76'</u>	<u>"</u>		

 ENTERS 1255 Kennett Ave. BRANCHED INTO 0
 TAP SIZE 1/2" PRESSURE 60 PSI _____ INCHES W C LOCATION 202' West
9' center of Elder Ct.
 PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY D. R.
 MAIN-SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1998
 DEPTH 2' FT 8" IN LOCATION 20' south of center of Kennett Ave.
 "A" P/S READING 11A TOTAL ANODES 1# 0 17# 0 LR # 74739
 REMARKS New 3/4" plastic service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Plastic
P/S Pipeline Lead - White Existing Main	E	115