

LOCATION 1262 Kennett Ave. CITY Gastonia  
BETWEEN Elder Ct. STREET & Heritage Commons STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
<del>service</del> MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>80'</u>	<u>2-12-01</u>		
<del>service</del> MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>0'</u>			
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>80'</u>			

ENTERS 1262 Kennett Ave. BRANCHED INTO  
TAP SIZE 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W/C LOCATION 73' west

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY D.R.  
center of Elder Ct.

*service* MAIN SIZE 3/4" C I \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 2000

DEPTH 1' FT 18" IN LOCATION 33' north of center of Kennett Ave.

"A" P/S READING 1114 TOTAL ANODES 1# 0 17# 0 LR # 00115269

REMARKS New 3/4" plastic service

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>riser</u>

