

LOCATION 1279 Kennett Ave CITY Boston MA
BETWEEN Elder Ct STREET & Heritage Commons STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>7/8"</u>	<u>P</u>	<u>70'</u>	<u>11/13/00</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>10'</u>	<u>"</u>		
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>60'</u>	<u>"</u>		

ENTERS 1279 Kennett Ave BRANCHED INTO Ø
TAP SIZE 1/2" PRESSURE 60 PSI _____ INCHES W C LOCATION 52' East of center of Elder Ct.

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY D. Woody
MAIN-SIZE 3" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1998
DEPTH 3' FT 0" IN LOCATION 22' south of center of Kennett Ave.

"A" P/S READING N/A TOTAL ANODES 1# Ø 17# Ø LR # 1073170

REMARKS new plastic 3/4" service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>riser</u>