

LOCATION 1279 Kennett ave. CITY Gastonia
 BETWEEN Elden ct. STREET & Hertige Company STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>55'</u>	<u>11/16/00</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>0</u>	<u>"</u>		
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>55'</u>	<u>"</u>		

ENTERS 1279 Kennett ave BRANCHED INTO 0
 TAP SIZE 3/4" PRESSURE 60 PSI INCHES W C LOCATION 52' East of center of Elden ct.


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY D. Wang

MAIN SIZE 3/4" C I 0 BARE STEEL 0 COATED STEEL 0 PLASTIC ✓ YEAR INSTALLED 2000

DEPTH 2' FT 0" IN LOCATION 30' south of center of Kennett ave.

"A" P/S READING N/A TOTAL ANODES 1# 0 17# 0 LR # 0

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>1.32</u>