


LOCATION 1609 K. AWAH CT CITY CASTANIABETWEEN WHITE HALL PL. STREET & Cal-de-Sue STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>70'</u>	<u>8-9-96</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>10'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>60'</u>			

ENTERS: 1609 BRANCHED INTO:TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 161' E. of center ofWhite Hall Pl.PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. Hull-StethMAIN-SIZE 2 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1994DEPTH: 3 FT. 0 IN. LOCATION 20' S. of center of K. AWAH CT"A" P/S READING _____ P TOTAL ANODES 1# 0 17# 0 L.R. # 434608

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY