

LOCATION 1633 KIAWAH CT. CITY GASTONIA
BETWEEN white Hall Pl. STREET & End of Culdesack STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>137'</u>	<u>5-22-96</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>PLASTIC</u>	<u>12'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>125'</u>			

ENTERS: 1633 BRANCHED INTO: 0
TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 427' S of E of white Hall Place


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY BL

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1994

DEPTH: 3 FT. 0 IN. LOCATION 38' W of E of KIAWAH CT.

"A" P/S READING PLASTIC N/A TOTAL ANODES 1# 0 17# 0 L.R. # 260384

REMARKS:

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser</u> <u>PLASTIC</u>	
	P/S Pipeline Lead - White Existing Main	<u>E</u>		