

LOCATION 314 Kozkapoo AveCITY GastoniaBETWEEN FallsSTREET & Green St

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>17'</u>			<u>5-5-98</u>
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>0</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>17'</u>			

ENTERS: 314BRANCHED INTO: ✓TAP SIZE: 3/4PRESSURE 60

PSI

INCHES W.C.

LOCATION


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. ElmoreMAIN SIZE 3/4 Std C.I. BARE STEEL COATED STEEL ✓ PLASTIC YEAR INSTALLED 1970DEPTH: 2 FT. 0

IN.

LOCATION

"A" P/S READING 1.1TOTAL ANODES 1# 17# L.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>Riser</u>	<u>Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY