

LOCATION 1632 Kimberly CITY Lorton
BETWEEN Old West Lane STREET & Belmar STREET

	SIZE	TYPE	Ø	LENGTH	5	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>		<u>2</u>	<u>74</u>		<u>Tied over 7-23-94</u>		
MAIN TO PROP. LINE	<u>3/4</u>		<u>2</u>	<u>37</u>				
PROP. LINE TO BLDG.	<u>3/4</u>		<u>0</u>	<u>37</u>				


ENTERS: 1632 BRANCHED INTO:
TAP SIZE: 1/2 PRESSURE _____ P.S.I. _____ INCHES W.C. LOCATION W side of house

PRESSURE TEST: @ 100 psi For 1/2 Hrs. By Bennett
MAIN-SIZE 2 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1993
DEPTH: 2 Ft. 6 In. LOCATION 17' W of C of Old West Lane

"A" P/S READING .40 TOTAL ANODES 1* 1 17* _____ L.R. # _____

REMARKS:

Bare Main Replacement
Program



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	1.20
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY