

LOCATION 204 N. King St CITY Gastonia  
BETWEEN W. Airline Ave STREET & RANKIN Ave STREET


|                     | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|---------------------|------|------|--------|-----------|---------|---------|
| MAIN TO BLDG.       | 3/4" | P    | 86'    | 11-23-98  |         |         |
| MAIN TO PROP. LINE  | 3/4" | P    | 20'    |           |         |         |
| PROP. LINE TO BLDG. | 3/4" | P    | 56'    |           |         |         |

ENTERS: 204 BRANCHED INTO:  
TAP SIZE: 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 168' N. of center of  
W. Airline Ave.

PRESSURE TEST: @ 100 PSI FOR 44 HRS. BY S. Huffstiller  
MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1997  
DEPTH: 3 FT. 0 IN. LOCATION 12' W. of center of N. King St

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 2233170

REMARKS:



| Test Station                               |          |       |
|--|----------|-------|
| Reading & Location                         | Lead     | Volts |
| P/S Pipeline Lead - Red<br>New Service     | <b>S</b> |       |
| P/S Pipeline Lead - White<br>Existing Main | <b>E</b> |       |

ENG. DEPT. USE ONLY