

LOCATION 200 King David Ln. CITY GASTONIA

BETWEEN King James Ln. STREET & Lowell - Bethesda STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>148'</u>	<u>12-5-96</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>75'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>73'</u>			

ENTERS: 200 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 41' S. of center of

King David Ln.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. HURST

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL ✓ PLASTIC _____ YEAR INSTALLED _____

DEPTH: 3 FT. 0 IN. LOCATION 21' W. of center of King James Ln.

"A" P/S READING .4 TOTAL ANODES 1# 0 17# 4 L.R. # 680729

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY