

LOCATION 203 King GEORGE LN. CITY GASTON, A
BETWEEN KING JAMES LN. STREET & KING ARTHUR STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>55'</u>	<u>2-26-98</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>7'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>48'</u>			


ENTERS: 203 BRANCHED INTO: 0
TAP SIZE: 3/8 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 184' E OF C of King JAMES LN.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY RL
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1977

DEPTH: 3 FT. 0 IN. LOCATION: 18' S OF C of King GEORGE LN.

"A" P/S READING 23 TOTAL ANODES 1# _____ 17# 1 L.R. # 453954

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>Plastic</u>

ENG. DEPT. USE ONLY