

LOCATION 215 King GEORGE LN CITY GASTONIA
BETWEEN King JAMES STREET & King ARTHUR STREET


| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|---------------------|------------|----------------|------------|----------------|---------|---------|
| MAIN TO BLDG. | <u>3/4</u> | <u>PLASTIC</u> | <u>60'</u> | <u>6-26-98</u> | | |
| MAIN TO PROP. LINE | <u>3/4</u> | <u>PLASTIC</u> | <u>5'</u> | | | |
| PROP. LINE TO BLDG. | <u>3/4</u> | <u>PLASTIC</u> | <u>50'</u> | | | |

ENTERS: 215 BRANCHED INTO: 0
TAP SIZE: 3/8 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 680' E OF C OF King JAMES LN.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY RL
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1977
DEPTH: 3 FT. 0 IN. LOCATION 17' S OF C OF King GEORGE LN.

"A" P/S READING .3 TOTAL ANODES 1# _____ 17# 1 L.R. # _____

REMARKS:



| Test Station | | |
|---|----------|----------------|
| Reading & Location | Lead | Volts |
| P/S Pipeline Lead - Red New Service <u>680' E OF C OF King JAMES LN.</u> | <u>S</u> | <u>RISKY</u> |
| P/S Pipeline Lead - White Existing Main <u>17' S OF C OF King GEORGE LN.</u> | <u>E</u> | <u>PLASTIC</u> |

ENG. DEPT. USE ONLY