

# SERVICE LOCATION RECORD

K	LOC	ACCT	SUB	WORK ORDER NO.	CITY NO.	KEY NO.	GRID NO.	CP NO.	PROJECT NO.
	700	892.00		505868	700	67	AP-38		

Tested 7' of 3/4" C/W pipe  
100 Psi 1/4 hr. 2-25-96  
E. Perry

