


LOCATION	223 King George Ln.			CITY	GASTONIA	
BETWEEN	King Arthur Ln.		STREET @	King James		STREET
	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	85'	1-31-95		
MAIN TO PROP. LINE	3/4"	P	5'			
PROP. LINE TO BLDG.	3/4"	P	80'			

ENTERS: 223		BRANCHED INTO:	
TAP SIZE: 1/2	PRESSURE 60 P.S.I.	INCHES W.C.	LOCATION 523' W. of center of King Arthur Ln.

PRESSURE TEST: @ 160 psi For 1/4 Hrs. By S. HUFFBLUTH			
MAIN-SIZE 2"	C.I. _____	BARE STEEL _____	COATED STEEL <input checked="" type="checkbox"/> PLASTIC _____
DEPTH: 4 Ft. In.			LOCATION 16' S. of center of King George Ln.

"A" P/S READING 1.0	TOTAL ANODES 1# 0 17# 0	L.R. # 32931
---------------------	-------------------------	--------------

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY