

LOCATION 2215 KINGS DR

CITY GASTONIA

BETWEEN ST. REGIS

STREET & CURTIS

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	80'	10-7-96		
MAIN TO PROP. LINE	"	"	8'			
PROP. LINE TO BLDG.	"	"	72'			

ENTERS: 2215

BRANCHED INTO: —

TAP SIZE: 1/2

PRESSURE _____ PSI _____ INCHES W.C.

LOCATION 26' W. of C of
KINGS DR

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY JP

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1970


DEPTH: 3 FT. 0 IN. LOCATION _____

"A" P/S READING 1.00

TOTAL ANODES 1# _____ 17# _____

L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	R	P
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY