

LOCATION SR 1187 Quality Built Homes (Kings Mt. Hwy) CITY Easton
BETWEEN Edgewood Rd STREET & Samble Loop STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>284</u>	<u>8-17-94</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>"</u>	<u>106</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>"</u>	<u>178</u>			

ENTERS: Quality Bldg. Homes BRANCHED INTO:
TAP SIZE: 3/8 PRESSURE _____ P.S.I. _____ INCHES W.C. LOCATION Side phone

PRESSURE TEST: @ 100 psi For 14 Hrs. By J. Smith
MAIN-SIZE 8 C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1968
DEPTH: 2 Ft. 6 In. LOCATION 16' N of Kings Mt. Hwy west Bound line

"A" P/S READING 1.30 TOTAL ANODES 1# _____ 17# _____ L.R. # 00344681

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY