

LOCATION 3411 Kings Mtn. Hwy CITY GASTONIA
BETWEEN Smith St STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>168'</u>	<u>12-11-95</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>0</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>168'</u>			


ENTERS: 3411 BRANCHED INTO:
TAP SIZE: 1/2 PRESSURE 600 P.S.I. INCHES W.C. LOCATION 115' S. of center of

Kings Mtn Hwy
PRESSURE TEST: @ 160 psi For 1/4 Hrs. By S. Huffaker
Service MAIN SIZE 3/4" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1992

DEPTH: 1 Ft. 6 In. LOCATION 110' E. of center of Smith St

"A" P/S READING 0 TOTAL ANODES 1* 0 17* 0 L.R. # 410806

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY