

LOCATION 3510 Kings Mtn. Hwy. Trailer # 114 CITY BASTOWIA  
BETWEEN Sante Circle Driveway STREET & Sante Circle in Trailer Park STREET <sup>entrance</sup>

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>GW</u>	<u>50</u>		<u>3-31-94</u>	
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						

ENTERS: Trailer No. 110 BRANCHED INTO: #114 Trailer  
TAP SIZE: 3/8 PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION 20' S of Co of Sante Circle


PRESSURE TEST: @ \_\_\_\_\_ psi For \_\_\_\_\_ Hrs. By \_\_\_\_\_

MAIN-SIZE 3/4 C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ☒ PLASTIC \_\_\_\_\_ YEAR INSTALLED \_\_\_\_\_

DEPTH: \_\_\_\_\_ Ft. 18 In. LOCATION 150' E of Co of Sante Circle <sup>entrance to Trailer</sup>  
<sub>off King Mt. Highway</sub>

"A" P/S READING 1.0 TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS: Retired 3/4 GW Service. Trailer installed All Electric  
Removed Riser purged with Air & Capped



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY