

LOCATION 4000 A Kings mtn Hwy

CITY GASTONIA

BETWEEN Barney castle

STREET &

Edgewood

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	Plastic	49'	11/10/95		
MAIN TO PROP. LINE	3/4"		49'			
PROP. LINE TO BLDG.	3/4"		49'			

ENTERS: 4000

BRANCHED INTO:

TAP SIZE: 1/2"

PRESSURE 60 P.S.I.

INCHES W.C.

LOCATION East side of 4000 A


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By DT

MAIN-SIZE 2' C.I. BARE STEEL COATED STEEL PLASTIC / YEAR INSTALLED 1995

DEPTH: 3 Ft. 0 In. LOCATION west side of 4000 B

"A" P/S READING 0 TOTAL ANODES 1* 0 17* 0 L.R. # 0580925

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY