

LOCATION 4020 Kings Mt. Hwy CITY Easton
BETWEEN Gamble Loop STREET & Edgewood Rd STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>3'</u>			
MAIN TO PROP. LINE				<u>Raised E.P. Riser</u>		
PROP. LINE TO BLDG.				<u>10-18-85</u>		

ENTERS: 4020 BRANCHED INTO: 4022

TAP SIZE: 3/4 PRESSURE 60 P.S.I. INCHES W.C. LOCATION


PRESSURE TEST: @ 100 psi For 114 Hrs. By EP. Used Tested Pipe Lot # 6595

MAIN-SIZE 3/4 C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED

DEPTH: 1 Ft. 6 In. LOCATION

"A" P/S READING P TOTAL ANODES 1# 17 # L.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY