

LOCATION 210 KIRKWOOD Dr. CITY East.
BETWEEN Broad st. STREET & Dead end STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>102'</u>		<u>9.</u>	<u>23-97</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>5'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>97'</u>			


ENTERS: JAME BRANCHED INTO:
TAP SIZE: 3/4" PRESSURE 100 PSI _____ INCHES W.C. LOCATION 172' From (C)
OF Broad st.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY N.F.
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 3 FT. 0 IN. LOCATION N. OF Kirkwood

"A" P/S READING P. TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY