LOCATION 4405 KNIGHTWOOD DR. CITY GASTONIA

BETWEEN BEDFORDSHIRE DR. STREET & DAWN WOOD DR. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	53'	03/31/95		
MAIN TO PROP. LINE	3/4	P	3'			
PROP. LINE TO BLDG.	3/4	P	50'			

ENTERS: 4405 BRANCHED INTO: —

TAP SIZE: 1/2 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By SP

MAIN-SIZE 2" C.I. ___ BARE STEEL ___ COATED STEEL ___ PLASTIC ✓ YEAR INSTALLED 1995

DEPTH: 3 Ft. 6 In. LOCATION 12" N. OF C OF BEDFORDSHIRE 18' W. OF C OF KNIGHTWOOD DR.

"A" P/S READING P TOTAL ANODES 1* P 17* P L.R. # —

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead – Red New Service	S	
P/S Pipeline Lead – White Existing Main	E	

ENG. DEPT. USE ONLY