

LOCATION 3003 Knollwood DR. CITY Gastonia

BETWEEN Shenandoah DR. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>		<u>Relocated</u>		
MAIN TO PROP LINE				<u>20' of</u>		
PROP LINE TO BLDG.				<u>Serv. with Plastic</u>		

ENTERS. Same BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI INCHES W.C. LOCATION

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY R.B.


PIPE SIZE 3/4" C I BARE STEEL COATED STEEL ✓ PLASTIC YEAR INSTALLED

DEPTH 3 FT 0 IN LOCATION 100' East of Knollwood DR. & 115' South of Shenandoah DR.

"A" P/S READING .9 TOTAL ANODES 1# 1 17# L.R. #

REMARKS:

Relocated Riser. Used 3/4" plastic to Relocate.
Use Tracer wire on Riser as a Test Point.



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>TRACER wire - .9</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	