

LOCATION 1505 Lake St CITY GASTONIA

BETWEEN Evening Shade STREET & Baker Blvd STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	75'	5-7-98		
MAIN TO PROP. LINE	3/4"	P	15'			
PROP. LINE TO BLDG.	3/4"	P	60'			

ENTERS: 1505 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 997' N. of center of Baker Blvd.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. Hufstetler

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1962

DEPTH: 3 FT. 0 IN. LOCATION 7' E. of center of Lake St

"A" P/S READING .85 TOTAL ANODES 1# 0 17# 0 L.R. # 294700

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY