

LOCATION 1233 LANDSDOWN DR

CITY GASTONIA

BETWEEN MONTROSE DR

STREET & HOLLANDALE DR

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	66'	6-6-94		
MAIN TO PROP. LINE	"	"	3'			
PROP. LINE TO BLDG.	"	"	63'			

ENTERS: 1233

BRANCHED INTO: —

TAP SIZE: 1/2

PRESSURE

P.S.I.

INCHES W.C.

LOCATION 23 W. of C of
LANDSDOWN DR


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By JF

MAIN-SIZE 2" C.I. — BARE STEEL — COATED STEEL — PLASTIC ☒ YEAR INSTALLED 1989

DEPTH: 3 Ft. 0 In. LOCATION

"A" P/S READING P. TOTAL ANODES 1* — 17* — L.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	SR	P
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY