

LOCATION 2310 LANTHERtree CT. CITY GASTONIA
BETWEEN Stoney Creek CT STREET & Cul-de-Sac STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>118'</u>	<u>4-16-98</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>45'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>73'</u>			


ENTERS: 2310 BRANCHED INTO:
TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 146' E. of center of
Stoney Creek CT

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. Hufschulte
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1997

DEPTH: 3 FT. 0 IN. LOCATION 19' S. of center of LANTHERtree CT.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 228211

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY