

LOCATION	2318 Lantertree Ct			CITY	GASTONIA	
BETWEEN	Stoney Creek Ct			STREET &	CUT DE - ST	
	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	3/4"	P	60'	7-24-00		
MAIN TO PROP LINE	3/4"	P	5'			
PROP LINE TO BLDG	3/4"	P	55'			

ENTERS	2318		BRANCHED INTO	
TAP SIZE	3/4"	PRESSURE	60 PSI	LOCATION 240' E of center of Stoney Creek Ct.

PRESSURE TEST @	100	PSI	FOR	44	HRS	BY	S.L.L.
MAIN-SIZE	2"	C.I.		BARE STEEL		COATED STEEL	
DEPTH	2 FT	0 IN	LOCATION	15' N. of center of Lantertree Ct.			

"A" P/S READING	P	TOTAL ANODES 1#	0	17#	0	LR #	672059
-----------------	---	-----------------	---	-----	---	------	--------

REMARKS

	Test Station		
	Reading & Location	Lead	Volts
	P/S Pipeline Lead - Red New Service	S	
	P/S Pipeline Lead - White Existing Main	E	