

LOCATION 2319 Lantentree Ct. CITY Boston  
 BETWEEN STREET & Cul-de-Sac STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>95'</u>	<u>6-23-99</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>10'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>85'</u>			

ENTERS: 2319 BRANCHED INTO:  
 TAP SIZE: 3/4" PRESSURE 60 PSI INCHES W C LOCATION 6' N. of center of Lantentree Ct.

PRESSURE TEST. @ 100 PSI FOR 1/4 HRS BY SA

MAIN SIZE 2" C I        BARE STEEL        COATED STEEL        PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 3 FT 0 IN LOCATION 264' E. of center of Stony Creek

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 I.R. # 483896

REMARKS:  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

