

LOCATION 916 Laurel LA.CITY GastoniaBETWEEN EighthSTREET & NOTTINGHAM

STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>C+W</u>	<u>54'</u>	<u>Tied over</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>C+W</u>	<u>1'</u>	<u>Exist service</u>		
PROP. LINE TO BLDG.	<u>3/4</u>	<u>C+W</u>	<u>53'</u>	<u>to 4' C.W. 1-288</u>		

ENTERS: 916 Laurel LA.

BRANCHED INTO:

TAP SIZE: ~~3/8~~ 3/8 PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 17' of Laurel LA.204' south of Eighth AvePRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY M.P.MAIN-SIZE 4" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ☒ PLASTIC \_\_\_\_\_ YEAR INSTALLED \_\_\_\_\_DEPTH: 3 FT. 6 IN. LOCATION 17' Laurel"A" P/S READING 1.7 TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. \_\_\_\_\_REMARKS: Tied Exist. service to 4' C+W

SERVICE  
Tie OVER'S  
LAUREL LN  
AREA



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>1.7</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY