

LOCATION 932 Laurel Ln. CITY Gastonia

BETWEEN Eighth St + Nottingham DR STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>RGW</u>			<u>Tied over</u>	
MAIN TO PROP. LINE	<u>11</u>	<u>11</u>			<u>8-2-97</u>	
PROP. LINE TO BLDG.	<u>11</u>	<u>11</u>				

ENTERS: 932 BRANCHED INTO: 940 & 942

TAP SIZE: 3/4 PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY DC

MAIN-SIZE 4" " C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ☒ PLASTIC \_\_\_\_\_ YEAR INSTALLED 1969

DEPTH: 3 FT. 6 IN. LOCATION East Side of Laurel Ln

"A" P/S READING .9 TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<b>S</b>	
P/S Pipeline Lead - White Existing Main	<b>E</b>	

ENG. DEPT. USE ONLY