


LOCATION 935 LAUREL LN. CITY GASTONIA  
 BETWEEN Nottingham STREET & 8th Ave STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>119'</u>	<u>B-30-00</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>44'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>74'</u>			

ENTERS: 935 BRANCHED INTO: 0  
 TAP SIZE: 1/8" PRESSURE 60 PSI INCHES W.C. LOCATION 354' S of Cor 8 Ave.  
 PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY DL  
 MAIN SIZE 4" C I        BARE STEEL        COATED STEEL        PLASTIC        YEAR INSTALLED 1969  
 DEPTH 3 FT 0 IN LOCATION 20' E of Cor Laurel LN.  
 "A" P/S READING 1.4 TOTAL ANODES 1#        17#        I.R. # 00780466  
 REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>1.4</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>1.4</u>

Plastic