

LOCATION 1031 Laurel Ln.CITY GASTONIABETWEEN Eighth Ave.STREET & Nottingham Dr.

STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>123'</u>	<u>10-17-97</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>41'</u>	<u>"</u>		
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>82'</u>	<u>"</u>		

ENTERS: 1031

BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 790' South of Center of Eighth Ave.PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY [Signature]MAIN-SIZE 4" C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1969DEPTH: 3 FT. 0 IN. LOCATION 17' East of Center of Laurel Ln."A" P/S READING 1.7 TOTAL ANODES 1# Ø 17# Ø L.R. # 706964

REMARKS:



Test Station

Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY