


LOCATION	1053 LAUREL LN.		CITY	GASTONIA		
BETWEEN	NORTHINGHAM DR		STREET @	EIGHT ST		STREET
	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3 1/4'	P	70'	9-26-95		
MAIN TO PROP. LINE	3 1/4'	P	10'			
PROP. LINE TO BLDG.	3 1/4'	P	60'			

ENTERS: 1053		BRANCHED INTO:	
TAP SIZE: 1/2	PRESSURE 40 P.S.I.	INCHES W.C.	LOCATION 68' N. of center of NORTHINGHAM DR

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By S. HUFFBACH			
MAIN-SIZE 2'	C.I. <input type="checkbox"/>	BARE STEEL <input checked="" type="checkbox"/>	COATED STEEL <input type="checkbox"/> PLASTIC <input type="checkbox"/> YEAR INSTALLED 1957
DEPTH: 3 Ft. 0 In.	LOCATION 10' W. of center of LAUREL LN.		

"A" P/S READING .7	TOTAL ANODES 1# 0 17# 1	L.R. # 487543
--------------------	-------------------------	---------------

REMARKS:
----------



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY