

LOCATION 1105 Laurel Ln CITY Casteria  
BETWEEN Nottingham STREET & 8th STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>D</u>	<u>18'</u>			
MAIN TO PROP. LINE	<u>3/4</u>	<u>D</u>	<u>2'</u>			<u>1-30-98</u>
PROP. LINE TO BLDG.	<u>3/4</u>	<u>D</u>	<u>16'</u>			

ENTERS: 1109 BRANCHED INTO: 1105  
TAP SIZE: 3/4 PRESSURE \_\_\_\_\_ PSI \_\_\_\_\_ INCHES W.C. LOCATION \_\_\_\_\_

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY EP  
MAIN-SIZE 3/4 C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1992  
DEPTH: 2 FT. 6 IN. LOCATION \_\_\_\_\_

"A" P/S READING D TOTAL ANODES 1# — 17# — I.R. # \_\_\_\_\_

REMARKS:  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY